

Approval Number 241155009
Test Report: PB2024002822 & PB2024003090



4th November 2024

Polymelt GmbH
Kimachstrasse 17,
87640 Ebenhofen,
Germany

Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

POLYPROPYLENE- COMPONENTS.

5260

'ECOSAN Fittings'. Green coloured, injection moulded PP-R fittings. For use with water up to 70°C.

APPROVAL NUMBER: 241155009
APPROVAL HOLDER: POLYMELT GMBH

The Scheme reserves the right to review approval.
Approval 241155009 is valid between November 2024 and November 2029

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes', is written over a horizontal line.

Ian Hughes
WRAS Approvals Manager